

ROMAC INDUSTRIES, INC.
STYLE FC400 COUPLING
WITH CLASS F FLANGE
SUBMITTAL INFORMATION

AWWA C219 The Romac Series 400 style couplings meets all specifications set forth in the AWWA Standard C219.

MATERIALS

Flange AWWA Class F Steel Ring Flange, compatible with ANSI Class 250 and 300 bolt circles.

End Ring and Body The end ring and body are made from ASTM A 36 steel or ductile (nodular) iron meeting or exceeding ASTM A 536, Grade 65-45-12. When anchor pins are requested on FC400's, the wall thickness of the body will be 3/8".

Gaskets Gaskets are made from rubber compounded for water and sewer service in accordance with ASTM D 2000 MBA810Z. Other compounds are available for petroleum, chemical, or high temperature service.

Bolts and Nuts High strength low alloy steel bolts and nuts. Steel meets AWWA Standard C111. Type 304 and 316 Stainless Steel bolt material optional.

Coatings Shop coat applied to parts for corrosion protection in transit. Fusion bonded epoxy, liquid epoxy and other coatings available on request.

PRESSURE When properly installed on a pipe that is within the coupling manufacturer's tolerances, Romac style FC400 Flanged Coupling Adapters can work at pressures up to the maximum rating of the flange. AWWA Class F flanges are rated for a working pressure of 300 psi. Higher working pressures can be accommodated consult your representative.

ANCHOR PINS Anchor pins (12L14 carbon steel) to restrain fitting, available as option.

SIZES AND RANGES See Catalog.

9/05

Romac Document Number 30-8-0019

This information is based on the best data available at the date printed above, please check with Romac Engineering Department for any updates or changes.