

# DJ400 DISMANTLING JOINT 14" - 72" WITH TIE RODS

## SUBMITTAL INFORMATION



## MATERIALS

### FLANGED

Spool AWWA Class D Steel Ring Flange, compatible with ANSI Class 125 and 150 bolt circles. Pipe is ASTM A36 plate 1% cold expanded to size.

### END RING AND BODY

The end ring and body are made from ASTM A36 steel.

### GASKETS

Compounded for water and sewer service. Meeting the requirements of ASTM D 2000. Other compounds available on request.

### BOLTS AND NUTS

ASTM A588 HSLA bolt material. Stainless Steel, Types 304 or 316 is optional.

### TIE RODS

High tensile steel per ASTM A193 grade B7. Stainless steel, type 304 or 316 is optional.

### COATINGS

Fusion bonded epoxy, NSF 61 certified.

## PRESSURE

When properly installed on a pipe that is within the coupling manufacturer's tolerances, Romac style DJ400 can work at pressures up to the maximum rating of the flange. AWWA Class D flanges are rated for 150 psi in 14" and larger sizes. Higher working pressures can be accommodated. Consult your representative.

## ASSEMBLY TOLERANCE

Three inch adjustment see catalog. For more length, contact Romac Engineering.

## SIZE

14"-72". SEE DRAWING FOR DETAIL. Sizes up to Ø170" are available.

## STANDARD

The DJ400 meet the specifications set forth in the AWWA Standard C219 coupling spec.

*This information is based on the best data available at the date printed above. Please check with Romac for any updates or changes.*